



NOTES:

1. DO NOT PLACE STONE UNDER CULVERT IN DIRECT CONTACT WITH POLYWRAP ON WATER MAIN
2. 36" MINIMUM CLEARANCE PER PUBLIC AGENCY PERMITS. 18" CLEARANCE UNDER STORM DRAIN LINES ON PRIVATE PROPERTY.
3. MAIN SHALL BE IN 10 LF CASING WITH SPACERS WHEN UNDER ANY DRAIN LINES GREATER THAN 18" OR A DITCH DRAINING INTO AN 18" CULVERT OR STORM DRAIN LINE. NO JOINTS ARE ALLOWED IN CASING.

VERTICAL OFFSET

CHARLESTON COMMISSIONERS OF PUBLIC WORKS		
VERTICAL OFFSET DETAIL		
APPROVED BY: CPW	DATE: NOV 1999	DRAWING NO. 6
SCALE: NTS	REVISED: AUG 2007	