



NOTES:

1. SEE MINIMUM STANDARDS FOR MATERIALS SPECIFICATIONS.
2. POST DEPTHS SHALL BE AS SPECIFIED BY MANUFACTURER BUT NOT LESS THAN 24".

PUMP STATION VEHICLE GATE

CHARLESTON WATER SYSTEM

PUMP STATION VEHICLE GATE

APPROVED BY: CWS	DATE: MAR 2000	DRAWING NO. 63
SCALE: NTS	REVISED: FEB 2010	